


Odour site visit checks

ST Classification: UNMARKED

Site Odour Check List Site name: Wanlip Time and Date: 20/11/2024 08:00am **Print Initials: ES** Circle: Reactive or Proactive (Record customer details in actions/next steps for Reactive complaints) 1. Wind direction 8. Weather conditions Specify...... 7mph East Specify - Frosty 2. Flows into works/ FFT 3600 L/S 9. Odour present at inlet channel? High (2800-3600 L/s) Medium (1300-2800 l/s) Low (0-1300 l/s) Actual flow -Medium 2132 L/S High 3. Odour present at on site SPS? Yes No Actions/Next Steps/ OOS Assets/ Any additional 4. Screenings and grit removed from site as per contact information regarding site issues etc. agreement (Inlet, PFT and CDE)? Biffa: Garage doors open 3 O/W PST 8 OOS Yes No N/W PST 2 OOS O/W Lane 2 Aerator 1 OOS 5. Out of service PST's drained and cleaned? O/W Lane 9 mixer 1 OOS O/W Lane 9 Aerator 3,5,6 OOS Yes No O/W Lane 11 Aerator 1 OOS O/W lane 15 mixer 4 OOS 6. Out of service PFT's drained and cleaned? O/W FST 5 OOS No Yes 7. PFT and PST Red Golden Measure ALB's? Yes No



Low