


Site Odour Check List Site name: Wanlip Time and Date: 28/10/2024 08:00am Print Initials: ES Circle: Reactive or Proactive (Record customer details in ac	ctions/next steps for Reactive complaints)	
1. Wind direction Specify 8mph N/E	8. <u>Weather conditions</u> Specify - Clear	
2. Flows into works/ FFT 3600 L/S		
High (2800-3600 L/s) (Medium (1300-2800 l/s)) Low (0-1300	1/s) 9. Odour present at inlet char	
<u>Actual flow -</u> 2154 L/S	High Medium	
3. Odour present at on site SPS?		
Yes No		
4. Screenings and grit removed from site as per contact agreement (Inlet, PFT and CDE)?	Actions/Next Steps/ OOS Assets/ Any a information regarding site issues etc. Biffa: Garage doors open 2	
Yes No	O/W PST 8 OOS N/W PST 2 OOS	
5. Out of service PST's drained and cleaned?	O/W Lane 1 Aerator 5 OOS O/W Lane 2 Aerator 1 OOS	
Yes No	O/W Lane 2 Aerator 1 00S O/W Lane 2 Aerator 4 00S O/W Lane 9 mixer 1 00S	
6. Out of service PFT's drained and cleaned?	O/W Lane 9 Aerator 3,5,6 OOS O/W Lane 11 Aerator 1 OOS	
Yes No	O/W Lane 13 Aerator 2 OOS O/W lane 15 mixer 4 OOS	
7. PFT and PST Red Golden Measure ALB's?	O/W Lane 16 Aerator 5 OOS O/W FST 5 OOS	
Yes No	2, 3. 3. 3	



10. Any odour present at plants operated by other businesses (e.g. Biffa)?



11. Is on site odour control working?



13. Any other operational issue potentially effecting odour?

YES	NO	

13. Any other known area odours?



Key:

- CDE screens = imported sludge screens
- PST = primary settlement tanks
- PFT = Picket Fence Thickener
- SPS = sewage pumping station
- ALB = action limit breach
- L/S = Litres per second
- FFT = Full flow treatment before we divert to storm tanks